



1099 Thompson Road, SE · Hartselle, AL 35640 · phone 256.773.2522

CERTIFICATE OF COMPLIANCE

March 24, 2010

To Whom It May Concern:

Cerro Wire LLC certifies that it's THHN/THWN is manufactured and tested in the USA in a manner that assures compliance with the following specifications.

- ANSI/UL 83 (file no. E15119)
- ANSI/UL 1063 (19, 37, and 61 strand) (file no. E85964)
- c(UL) Listed - Type TWN75 complies with Canadian Standard C22.2 No. 75 and CSA Bulletin No. 1451. Type T90 Nylon complies with Canadian Standard C22.2 No. 75.
- NEMA WC70/ICEA S-95-658
- Federal Specification A-A-59544
- ASTM B3, B8, B787
- National Electric Code, NFPA 70
- 14 AWG through 1 AWG are rated VW-1
- Sizes 8 AWG and larger are rated THWN-2
- Sizes 8 AWG through 1 AWG in black are rated sunlight resistant
- Sizes 1/0 and larger are rated sunlight resistant, for cable tray use
- RoHS compliant

Sincerely,

A handwritten signature in black ink that reads "Richard C. Bennett".

Richard C. Bennett
Director of Quality

