

CERTIFICATE OF COMPLIANCE

April 28, 2008

Cerro Wire Inc. certifies that its USE-2 is manufactured and tested in a manner that assures compliance with the following specifications.

- UL 44 (RHH or RHW-2)
- UL 854 (USE-2), File No. E63541
- UL Flexibility Test of Cable at Low Temperature at -25°C per UL 854, section 21.1
- Cross – Linked Polyethylene Insulation (XLP)
- For use as RHH or RHW-2 in wet or dry locations at temperatures up to 90°C
- Sunlight Resistant
- Gasoline & Oil Resistant I & II
- ASTM – B3
- ASTM – B8
- Federal Specification A-A-59544
- National Electric Code



Richard C. Bennett
Director of Quality