

CERTIFICATE OF COMPLIANCE

April 28, 2008

Cerro Wire Inc. certifies that its XHHW-2 is manufactured and tested in the USA in a manner that assures compliance with the following specifications.

- UL 44 – File No. E63539
- CSA LL82214
- Rated RW90 per Canadian Standards
- Passes CSA's cold impact test at -40°C
- Cross – linked Polyethylene Insulation
- Sunlight Resistant
- For use in wet or dry locations at temperatures up to 90°C
- 1/0 and larger rated for use in Cable Trays
- ASTM – B3
- ASTM – B8
- ASTM – B787
- Federal Specification A-A-59544
- National Electric Code
- NEMA WC70/ICEA S-95-658-1999



Richard C. Bennett
Director of Quality